

Public Notice

As required by Knox County Air Quality Management Regulation (KCAQMR) Section 25.1-E, the Knox County Department of Air Quality Management (KCDQM) is providing the public the opportunity to submit written comments on the proposed construction and/or modification of air contaminant source(s) as noted below.

Knoxville Utility Board has applied to modify the existing digester gas boilers at the Wastewater Treatment facility located at 2015 Neyland Drive, Knoxville, TN 37916. The requested modification is to replace the three (3) existing 4.0 MMBtu/hr digester gas boilers with two (2) 6.695 MMBtu/hr digester gas boilers. Questions concerning the source(s) may be addressed to David Colvin at (865) 215-5900 or by e-mail at dcolvin@aqm.co.knox.tn.us.

To be considered, written comments must be received no later than September 6, 2018 and be submitted using one of the following methods:

1. **Mail, private carrier, or hand delivery:** Address written comments to Knox County Department of Air Quality Management, 140 Dameron Avenue, Knoxville, TN 37917
2. **E-mail:** Submit electronic comments to aqm@aqm.co.knox.tn.us.

For further information please call (865) 215-5900.